



# O&M Service Checklist

## LANDSAVER™ MBR

**Installation Address:** \_\_\_\_\_  
Street City State Zip

LandSaver™ MBR treatment systems should be serviced every six months and samples submitted per state and local regulations. Please consult the Service Manual while performing this checklist.

Action	Completed
Check alarm functionality using the alarm test switch located on the control panel. If an alarm is already active, follow the <b>Troubleshooting Guide</b> to diagnose the problem.	
Remind homeowner that the only normal yard traffic, such as mowing the lawn, is acceptable near where the Tangent LandSaver™ MBR tankage was installed.	
Perform routine inspection of Tangent LandSaver™ MBR tankage and risers to ensure they have not been damaged by excessive weight loading.	
Clear tank vents and blower housing intakes of any obstructions that may impact performance.	
Check the transfer pump, Sludge Pump, Blower, UV bulb life, and Ultrafilter permeate pump operation.	
Check the float switches' and level transmitter's operation.	
Collect regulatory sample as required in compliance with local regulations.	
Perform Clean-In-Place (CIP) procedure on Ultrafilter Unit	
Check Ultrafilter UV sleeve for clarity. Clean if necessary	
Perform solids removal procedure, if necessary.	

*\* For additional tank information reference Infiltrator's IM-Series Septic Tank General Installation Instructions.*

Notes:

---

---

---

---

---

---

---

---

**Service Provider:** \_\_\_\_\_  
Print Company Name

\_\_\_\_\_ **Print Representative Name**

**Date Service Completed:** \_\_\_\_\_

\_\_\_\_\_ **Signature**

**Return Completed Form to:**

[info@tangentcompany.com](mailto:info@tangentcompany.com)

OR

Tangent Company LLC  
 10175 Queens Way Unit 1  
 Chagrin Falls, Ohio 44023