

Acceptable Automatic Pool Chemical Controllers

The automatic chemical controller units listed below have been reviewed and approved by the Ohio Department of Health (ODH) in accordance with Ohio Administrative Code (OAC) 3701-31-04(D)(7). This rule sets forth minimum functional requirements for automatic chemical controllers whether they are installed on public spas, public swimming pools, special features or spraygrounds. This requirement became effective January 1, 1999 with the specifications for these units modified in April 2011 to require the monitoring and display of both pH and oxidation-reduction potential (ORP). According to OAC 3701-31-02(G)(3) the director shall maintain a list of controllers that meet these requirements. **This is not a comprehensive list.** If a unit is not on this list but meets the specifications of 3701-31-04(D)(7)(a) through 3701-31-04(D)(7)(d), the operator may submit the unit for review. Please contact the public swimming program at (614)644-7438 for information on the submittal process.

| <u>Manufacturer</u> | <u>Unit</u> | | | |
|--|---|---|----------------------------|----------------------------|
| AquaCal AutoPilot, Inc. 5841 Powerline Road Ft. Lauderdale, FL 33309 | Pool Pilot Total Control complete with acid feeder and pH | | | |
| Aquasol Controllers, Inc. 1707 Townhurst Dr. Houston, TX 77043 | Aquasol Controller Models | WTC | XPC | |
| BECS Technology 9487 Dielman Rock Island Ind. Dr. Saint Louis, MO 63132 | BECS Technology Models | BECSys2 BECSys3 | BECSys5 BECSys7 | |
| Chemtrol 5375 Overpass Road Santa Barbara, CA 93111 | Chemtrol Models | 250 PC2000 PC2100 | PC3000 PC5000 PC5100 | PC6000 PC7000 PC7100 |
| ControlOMatic, Inc. 12659 Arbor Lane Grass Valley, CA 95949 | ControlOMatic Models | MiniWarden PoolWarden D PoolWarden S | | |
| Ecolab Inc. 655 Lone Oak Drive Building F, Floor 6 Eagan, MN 55121 | Ecolab Inc. Models | AK2100-D AK2100-S AB-300 | | |
| Evoqua Water Technologies LLC 6713 Falcon Pointe Road Wilmington, NC 28411 | Evoqua Model | Blu-Sentinel Blu-Sentinel SE Blu-Sentinel Pro | | |
| Hayward Commercial Pool Products 10101 Molecular Drive #200 Rockville, MD 20850 | Hayward CAT Controllers Model | CAT 2000 CAT 4000 CAT 5000 HCC2000 HCC2000-CP | | |
| Integrated Aquatic Environments, Inc. 1600 Milwaukee Avenue Suite 703 Lake Villa, IL 60046 | HALO Model controller | | | |
| IPS Controllers 2611 Ynez Road, Suite C-4 Temecula, CA 92591 | IPC Controller Models | M790 M820 M920 | | |

Acceptable Automatic Pool Chemical Controllers

| | | |
|--|---|---|
| National Aquatics Distributors, Inc. 24551 Production Cr. Unit #2 Bonita Springs, FL 34135 | Siemens Strantrol model Siemens Strantrol model Siemens Strantrol model | Set Point NX Compact Pool |
| Pentair Aquatic Systems 10951 West Los Angeles Ave. Moorpark, CA 93012 | Pentair models | IntelliChem PN 521357 AcuTrol AK110PD-CD |
| ProMinent Fluid Controls 136 Industry Drive Pittsburgh, PA 15275 | ProMinent Controllers Series ProMinent Controllers Series | DCM 2 DCM 5 |
| Pulsafeeder, SPO 27101 Airport Road Punta Gorda, FL 33982 | Pulsablue model | #C3313 with the pH option |
| Rola-Chem Corp. 5858 Centerville Road St. Paul, MN 55127 | Rola-Chem Corp. models | RC554XXP – Dual ORP / pH Controller RC554XP – ORP / pH Controller |
| Zodiac Pool Systems, Inc. 2620 Commerce Way Vista, CA 92081-8438 | Polaris Watermatic Controller Models | C2000 C660 |
| H.W. Rhodes Inc. 5511 Brampton Road Dayton, OH 45429 | Chemcon Model 12 HWR Model 12 | |
| TMI Sustainable Aquatics P.O. Box 433 Manchester, WA 98353 | EMCD-i RSC-1 Series RSC-3 Series | |